



DATE: August 7, 2024

FROM: Elkhart County Park & Recreation Board
211 W. Lincon Avenue
Goshen, IN 46526

TO: Prospective Bidders

RE: Addendum #1 to the Bidding Documents for
Hexagon Shaped Steel Picnic Shelter with Double-Tier Roof
at Corson Riverwoods County Park

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents as noted below. Please acknowledge receipt of the Addendum by notation on the provided Bid Sheet and inclusion of this Addendum No. 1 in the submitted bid documents.

Failure to do so may subject the Bidder to disqualification.



ELKHART COUNTY PARK & RECREATION BOARD SPECIFICATION CLARIFICATIONS TO SPECIFICATION SUMMARY:

In response to bidder questions regarding Elkhart County Park & Recreation Board Bid Documents for the Hexagon Shaped Steel Picnic Shelter with Double-Tier Roof at Corson Riverwoods County Park, the following clarifications are provided:

1. Item #7 in the Specification Summary of the Bid Documents mentions "the underside (ceiling) must include synthetic underlayment or equal." Questions have been received regarding specifications for the roof deck. The roof deck must be 2" X 6" (nominal, #1 grade, single tongue and groove with V-joint on bottom face; a species of kin dried southern yellow pine or the equivalent; maximum moisture content of 19%, with all joints over supports. In light of this rood deck requirement, synthetic underlayment or equal is optional.

END OF ADDENDUM NO. 1

**CONTRACTOR SHOULD ACKNOWLEDGE RECEIPT OF THIS ADDENDUM AS PART
OF THE SUBMITTED BID DOCUMENTS**